



Western Avenue WQARF Site

Western Avenue/Phoenix Goodyear Airport

CAG Meeting of February 6, 2014

Delfina Olivarez




Update on Site Activities


- **Quarterly Groundwater Quality sampling conducted November 06, 2013 results from Western Avenue Monitoring Wells and the City of Goodyear well No. 1(COG-01)were similar to August results and in historical range for the site.**

Update on Site Activities



- **The City of Goodyear Well No. 1(COG-01) was not operating prior to arriving for sampling. PCE was detected at a concentration of 4.2 ug/l. This concentration is below Aquifer Water Quality Standards of 5 ug/l, is in agreement with previous sampling events where the well was not operating prior to ADEQ sampling and further supports the conclusions presented in the Well COG-01 Time-Series Groundwater Sampling Report, dated November 1, 2013.**

Western Avenue WQARF Site






Western Avenue WQARF Site



WESTERN AVENUE WQARF SITE
GROUNDWATER ELEVATION AND TETRACHLOROETHENE CONCENTRATIONS

Western Avenue & PGA Plumes



PHOENIX-GOODYEAR AIRPORT (PGA) AREA SITES SUBUNIT A PLUMES

Upcoming Activities at Western Avenue

- Next quarterly monitoring event, including water quality sampling and water level gauging of the 8 Western Avenue Wells and the COG-01 will be February 12, 2014.
- Please visit:
<http://www.azdeq.gov/environ/waste/sps/phxsites.html#westavea> for site information and updates.



Western Avenue WQARF Site

Thank You-Questions

Delfina Olivarez

Western Avenue Project Manager

602-771-4710, dco@azdeq.gov;

Wendy Flood Western Avenue Community

Involvement Coordinator

602-771-4410, wv1@azdeq.gov