


GROUND FLOOR PLAN

- TRANSFER WASTE STORAGE
- PALLET STORAGE FOR PRODUCT SOLVENTS I/C, THINNER AND 150.
- PERMITTED WASTE STORAGE

**STORAGE ARRANGEMENT**  
 5 CONTAINERS/PALLET X 30 GAL/CONTAINER X 2 PALLETS/STACK X 23 STACKS = 6900 GALLONS

**CONTAINMENT SPECIFICATIONS**  
 FLOOR AREA CONTAINMENT AVAILABLE = 1,703 GALLONS  
 TRENCH CAPACITY = 457 GALLONS  
 TOTAL CONTAINMENT AVAILABLE = 2,160 GALLONS  
 CONTAINMENT REQUIRED = 10% OF 6,900 = 690 GALLONS  
 EXCESS CONTAINMENT = 1470 GALLONS



SECOND FLOOR PLAN

INVENTORY STORAGE PLAN

**PROPRIETARY STATEMENT**

THIS DRAWING IS THE EXCLUSIVE PROPERTY OF SAFETY-KLEEN CORP. AND IS PROPRIETARY AND CONFIDENTIAL INFORMATION. THIS DRAWING AND THE INFORMATION CONTAINED THEREIN MUST NOT BE DUPLICATED, USED, DIVULGED, REPRODUCED, COPIED, DISCLOSED OR APPROPRIATED IN WHOLE OR IN PART FOR ANY PURPOSE OTHER THAN AS EXPRESSLY AUTHORIZED BY SAFETY-KLEEN CORP. THIS DRAWING MUST BE RETURNED PROMPTLY UPON REQUEST.

**Project Solutions**  
 Companies

1300 Boone Industrial Drive • Suite 200 • Columbia • MD 66202  
 • Phone: (873) 443-7100 • Fax: (873) 443-7181 •

NO.	DESCRIPTION	BY	CHK	APPR	DATE
1	REVISE TO SHOW CURRENT STORAGE CONDITIONS	JEK	-	-	041405
1	UPDATE TO SHOW 12K AGT FOR PART B	JEK	-	-	042804

TITLE

**FLOOR PLAN  
OFFICE/WAREHOUSE**

**SAFETY-KLEEN CORP.**  
 5489 LEGACY DR. CLUSTER III BLDG 3 PLANO, TX. 75024 800-669-5740

SCALE: 1/8"=1'  
 BY WEY CHKD WEY P.E. APPR - DP. APPR - DATE 12-10-93

SERVICE CENTER BRANCH AT CHANDLER, AZ  
 STD-DWG-REV NO. 7134-WB00-003-2