

**Arizona Department of Environmental Quality  
 Drinking Water Analytical Report  
 Stage 2 Disinfection By-Products (TTHM & HAA5), Operational Evaluation Level Report  
 Limited Scope – Treatment**

<b>Treatment Process Evaluation Checklist</b>		Page 1 of 4
<input type="checkbox"/> <b>NO DATA AVAILABLE</b>		
Facility Name: _____		PWS ID: AZ04-
Checklist Completed by: _____		Date: _____
A.	Review finished water data for the time period prior to the OEL exceedance(s) and compare to historical finished water data using the following questions:	
	Were DBP precursors (TOC, DOC, SUVA, bromide, etc.) higher than normal?	<input type="checkbox"/> Yes <input type="checkbox"/> No
	Was finished water pH higher or lower than normal?	<input type="checkbox"/> Yes <input type="checkbox"/> No
	Was the finished water temperature higher than normal?	<input type="checkbox"/> Yes <input type="checkbox"/> No
	Was finished water turbidity higher than normal?	<input type="checkbox"/> Yes <input type="checkbox"/> No
	Was the disinfectant concentration leaving the plant(s) higher than normal?	<input type="checkbox"/> Yes <input type="checkbox"/> No
	Were finished water TTHM/HAA5 levels higher than normal?	<input type="checkbox"/> Yes <input type="checkbox"/> No
	Were operational and water quality data available to the system operator for effective decision making?	<input type="checkbox"/> Yes <input type="checkbox"/> No
B.	Does the treatment process include pre-disinfection? <span style="float: right;"><input type="checkbox"/> Yes    <input type="checkbox"/> No</span>	
	<b>If NO, proceed to item C. If YES, answer the following questions for the period in which an OEL exceedance occurred:</b>	
	Yes    No	
	<input type="checkbox"/> <input type="checkbox"/>	Was disinfected raw water stored for an unusually long time?
	<input type="checkbox"/> <input type="checkbox"/>	Were treatment plant flows lower than normal?
	<input type="checkbox"/> <input type="checkbox"/>	Were treatment plant flows equally distributed among different trains?
	<input type="checkbox"/> <input type="checkbox"/>	Were water temperatures high or warmer than usual?
	<input type="checkbox"/> <input type="checkbox"/>	Were chlorine feed rates outside the normal range?
	<input type="checkbox"/> <input type="checkbox"/>	Was a disinfectant residual present in the treatment train following pre-disinfection?
	<input type="checkbox"/> <input type="checkbox"/>	Were online instruments utilized for process control?
	<input type="checkbox"/> <input type="checkbox"/>	Did you switch to free chlorine as the oxidant?
	<input type="checkbox"/> <input type="checkbox"/>	Was there a recent change (or addition) of pre-oxidant?
	<input type="checkbox"/> <input type="checkbox"/>	Did you change the location of the pre-disinfection application?

**Arizona Department of Environmental Quality**  
**Drinking Water Analytical Report**  
**Stage 2 Disinfection By-Products (TTHM & HAA5), Operational Evaluation Level Report**  
**Limited Scope – Treatment**

**Treatment Process Evaluation Checklist** Page 2 of 4

C. Does your treatment process include presedimentation?  Yes  No

**If NO, proceed to item D. If YES, answer the following questions for the period in which an OEL exceedance occurred:**

Yes      No

- Were flows low?
- Were flows high?
- Were online instruments utilized for process control?
- Was sludge removed from the presedimentation basin?
- Was sludge allowed to accumulate for an excessively long time?
- Do you add a coagulant to your presedimentation basin?
- Was there a problem with the coagulant feed?

D. Does your treatment process include coagulation and/or flocculation?  Yes  No

**If NO, proceed to item E. If YES, answer the following questions for the period in which an OEL exceedance occurred:**

Yes      No

- Were there any feed pump failures or were feed pumps operating at improper feed rates?
- Were chemical feed systems controlled by flow pacing?
- Were there changes in coagulation practices or the feed point?
- Did you change the type or manufacturer of the coagulant?
- Do you suspect that the coagulant in use at the time of the OEL exceedance did not meet industry standards?
- Did the pH or alkalinity change at the point of coagulant addition?
- Were there broken or plugged mixers?
- Were flow rates above the design rate or was there short-circuiting?

E. Does your treatment process include sedimentation or clarification?  Yes  No

**If NO, proceed to item F. If YES, answer the following questions for the period in which an OEL exceedance occurred:**

Yes      No

- Were there changes in plant flow rate that may have resulted in a decrease in settling time or carry-over of process solids?
- Were settled water turbidities higher than normal?
- Was there any disruption in the sludge blanket that may have resulted in carryover to the point of disinfection?
- Was there any maintenance in the basin that may have stirred sludge from the bottom of the basin and caused it to carry over to the point of disinfectant addition?
- Was sludge allowed to accumulate for an excessively long time or was there a malfunction in the sludge removal equipment?

**Arizona Department of Environmental Quality**  
**Drinking Water Analytical Report**  
**Stage 2 Disinfection By-Products (TTHM & HAA5), Operational Evaluation Level Report**  
**Limited Scope – Treatment**

**Treatment Process Evaluation Checklist**

F. Does your treatment process include filtration?  Yes  No

**If NO, proceed to item G. If YES, answer the following questions for the period in which an OEL exceedance occurred:**

Yes      No

- Was there an increase in individual or combined filter effluent turbidity or particle counts?
- Was there an increase in turbidity or particle loading onto the filters?
- Was there an increase in flow onto the filters or malfunction of the rate of flow controllers?
- Were any filters taken off-line for an extended period of time that caused the other filters to operate near maximum design capacity and creating the conditions for possible breakthrough?
- Were any filters operated beyond their normal filter run time?
- Were there any unusual spikes in individual filter effluent turbidity (which may indicate particulate or colloidal TOC breakthrough) in the days leading to the excursion?
- Were all filters run in a filter-to-waste mode during initial filter ripening?
- If GAC filters are used, is it possible the adsorptive capacity of the GAC bed was reached before reactivation occurred (leave blank if not applicable)?
- If biological filtration is used, were there any process upsets that may have resulted in the breakthrough of TOC (leave blank if not applicable)?

G. Does your treatment process include primary disinfection by injecting chlorine prior to a clearwell?  Yes  No

**If NO, proceed to item H. If YES, answer the following questions for the period in which an OEL exceedance occurred:**

Yes      No

- Was there a sudden increase in the amount of chlorine fed or an increase in the chlorine residual?
- Was there an increase in clearwell holding time?
- Was the plant shut down or were plant flows low?
- Was there an increase in clearwell water temperature?
- Did you switch to free chlorine recently as the primary disinfectant?
- Was the inactivation of *Giardia* and/or viruses exceptionally high?
- Was there a change in the mixing strategy (i.e. mixers not used, adjustment of tank level)?

H. Does your plant recycle spent filter backwash or other streams?  Yes  No

**If NO, proceed to item I. If YES, answer the following questions for the period in which an OEL exceedance occurred:**

Yes      No

- Did a change in the recycle stream quality contribute to increased DBP precursor loading that was not addressed by treatment plant processes?
- Did a recycle event result in flows in excess of typical or design flows?

**Arizona Department of Environmental Quality  
 Drinking Water Analytical Report  
 Stage 2 Disinfection By-Products (TTHM & HAA5), Operational Evaluation Level Report  
 Limited Scope – Treatment**

**Treatment Process Evaluation Checklist**

I. Do you inject a disinfectant after your clearwell to maintain a distribution system residual?  Yes  No

**If NO, proceed to item J. If YES, answer the following questions for the period in which an OEL exceedance occurred:**

Yes No

- Was there a sudden increase in the amount of chlorine fed?
- Was there a switch from chloramines to free chlorine for a burnout period?
- If using chloramines, was the chlorine to ammonia ratio in the proper range?
- Was there a problem with either chlorine or ammonia mixing?

J. Did concern about complying with a rule other than Stage 2 DBPR, such as the Lead and Copper rule, the LT2ESWTR, or any other rule constrain your options to reduce the DBP levels at this site? For example, are you limited by other treatment targets/requirements in your ability to control precursors in coagulation/flocculation?  Yes  No

**If NO, proceed to item K. If YES, explain below and consult EPA's *Simultaneous Compliance Guidance Manual* for alternative compliance approaches.**

---



---



---



---

**K. Conclusion**

Did treatment factors and/or variations in the plant performance contribute to the OEL exceedance(s)?  Yes  No  
 Possibly

**If YES or POSSIBLY, explain below.**

---



---



---



---



---



---



---



---

**Please mail completed form to:**  
 Arizona Department of Environmental Quality  
 Water Quality Data Unit, MC 5415B-1  
 1110 West Washington Street  
 Phoenix, AZ 85007

**Questions Regarding TTHM / HAA5:**  
 Call (602) 771-4641  
 Within AZ (800) 234-5677, ext. 771-4641  
 Fax (602) 771-4505